



Decorative Fireplace Inspection Checklist

*This list comprises some of the most common code violations when installing a decorative fireplace. It **does not** address every possible violation, **nor** is it intended as an instruction manual.*

Decorative Fireplace Inserts

- ☐ Insert units must be listed, (ICBO, AGA, WH or UL) or approved prior to installation.
- ☐ Manufacturer installation instructions to be followed on all listed units.
- ☐ Gas lines to decorative appliances to comply with checklist for gas line extensions.
- ☐ Decorative appliance insert venting to comply with manufacturer's requirements. Chimney may be used as a vent only if it meets all conditions of UMC section 813
- ☐ Combustion air for gas fired appliances must be provided as required by UMC chapter 7
- ☐ Installation instructions for the insert to be left on site for the inspector's use.